

**AMENDMENT NO. 2 MARCH 2002  
TO  
IS 13920 : 1993 DUCTILE DETAILING OF REINFORCED  
CONCRETE STRUCTURES SUBJECTED TO SEISMIC  
FORCES — CODE OF PRACTICE**

( Page 1, clause 1.1.1 ) —Substitute the following for the existing:

**'1.1.1 Provisions of this code shall be adopted in all reinforced concrete structures which are located in seismic zone III, IV or V.'**

( Page 3, clause 5.2, line 3 ) — Delete the word 'preferably'.

( Page 3, clause 5.3 ) — Insert the following at the end of the clause:

**'However, high strength deformed steel bars, produced by the thermo-mechanical treatment process, of grades Fe 500 and Fe 550, having elongation more than 14.5 percent and conforming to other requirements of IS 1786 : 1985 may also be used for the reinforcement.'**

( CED 39 )

470381508  
(i)