

IS 4031 (Part 15) : 1991
(Reaffirmed 1995)

भारतीय मानक

जलदृढ़ी सीमेंट के लिए भौतिक परीक्षण की पद्धतियाँ

भाग 15 आर्द्र छन्नी द्वारा बारीकी ज्ञात करना

Indian Standard

**METHODS OF PHYSICAL TESTS FOR
HYDRAULIC CEMENT**

PART 15 DETERMINATION OF FINENESS BY WET SIEVING

Second Reprint OCTOBER 1997

UDC 66·942 : 620·168·32

© BIS 1991

BUREAU OF INDIAN STANDARDS
MANAK BHAVAN, 9 BHADUR SHAH ZAFAR MARG
NEW DELHI 110002

June 1991

Price Group 3

FOREWORD

This Indian Standard was adopted by the Bureau of Indian Standards, after the draft finalized by the Cement and Concrete Sectional Committee had been approved by the Civil Engineering Division Council.

Standard methods of testing cement are essential adjunct to the cement specifications. This standard in different parts, lays down the test procedures to evaluate the physical properties of different types of hydraulic cement. This part covers determination of fineness of cement by wet sieving. The procedures for conducting chemical tests of hydraulic cement are covered in IS 4032 series 'Methods of chemical analysis of hydraulic cement'.

Determination of fineness by wet sieving is required mainly for masonry cement, but the same method shall be applied when any manufacturer or user wants to determine fineness of any other cement for any other specific reason.

The composition of the technical committee responsible for the formulation of this standard is given in Annex A.

In reporting the results of a test or analysis made in accordance with this standard, if the final value, observed or calculated, is to be rounded off, it shall be done in accordance with IS 2 : 1960 'Rules for rounding off numerical values (*revised*)'.

Indian Standard

METHODS OF PHYSICAL TESTS FOR HYDRAULIC CEMENT

PART 15 DETERMINATION OF FINENESS BY WET SIEVING

1 SCOPE

This standard (Part 15) covers the procedure for determining the fineness of cement by wet sieving as represented by the mass of the residue left on a standard 45-micron IS Sieve.

2 REFERENCES

The Indian Standards listed below are necessary adjuncts to this standard.

<i>IS No.</i>	<i>Title</i>
3535 : 1986	Methods of sampling hydraulic cements (<i>first revision</i>)
460 (Part 1) : 1985	Specification for test sieves: Part 1 Wire cloth test sieves (<i>third revision</i>)

3 SAMPLING AND SELECTION OF TEST SAMPLES

The samples of the cement shall be taken in accordance with the requirements of IS 3535 : 1986 and the relevant standard specification for the type of cement being tested. The representative sample of the cement selected as above shall be thoroughly mixed before testing.

4 TEMPERATURE

The temperature of the room and the materials shall preferably be maintained at $27 \pm 2^\circ\text{C}$.

5 APPARATUS

5.1 Sieve

The sieve frame shall be of non-corrodible material and shall be circular 50 ± 5 mm in diameter. The depth of the sieve from the top of the frame to the cloth shall be 75 ± 5 mm. The frame shall have either side walls 90 ± 5 mm in total height or legs of sufficient length, 12.0 mm minimum, to allow air circulation beneath the sieve cloth. The sieve frame shall be fitted with 45 micron stainless steel woven wire cloth sieve conforming to IS 460 (Part 1) : 1985. The cloth shall be mounted in the frame without distortion, looseness or wrinkling. For a sieve fabricated by soldering the cloth to the frame, the joint shall be made smooth to prevent the cement from catching in the joints between the sieve cloth and frame. Two piece

sieves shall clamp tightly on the cloth to prevent the cement from catching in the joints between the sieve cloth and the frame.

5.2 Spray Nozzle

The spray nozzle (see Fig. 1) shall be constructed with non-corrodible material and shall be of 17.5 mm inside diameter with a central hole drilled in line with the longitudinal axis, and intermediate row of eight holes drilled 6 mm centre to centre at an angle of 5° from the longitudinal axis, and an outer row of eight holes drilled 11 mm centre to centre at an angle of 10° from the longitudinal axis. All holes shall be of 0.5 mm diameter.

5.3 Pressure Gauge

The pressure gauge shall be of 75 mm minimum diameter and shall be graduated in 0.01 N/mm^2 increments and shall have a maximum capacity of 0.2 N/mm^2 with a marking at 0.07 N/mm^2 . The accuracy at 0.07 N/mm^2 shall be 0.005 N/mm^2 .

5.4 Balance

Analytical balance capable of reproducing results within 0.000 2 g with an accuracy of $\pm 0.000 2$ g.

NOTE — Self indicating balance with equivalent accuracy may also be used.

5.5 Standard Weights

5.6 Oven

6 CALIBRATION OF 45 MICRON IS SIEVE

The calibration of the 45 micron sieve shall be made using standard reference material (SRM) from National Council of Cement and Building Materials. Place 1.000 g of the SRM on the clean dry 45 micron sieve and proceed as in 7. The sieve correction factor is the difference between the test residue obtained and the assigned residue value indicated by the electro-formed sheet sieve fineness specified for the standard sample, expressed as a percentage of the test residue. The sieve shall be re-calibrated after every 100 determinations.

Example :


Residue on 45 micron IS Sieve of 14.0 percent SRM sample

Residue for a 1 g sample 0.140 g


Residue on Sieve being calibrated 0.105 g

Difference +0.035 g

Correction factor = $\frac{0.035 \times 100}{0.105} = +33.3$ percent



SPRAY NOZZLE ASSEMBLY



All dimensions in millimetres.

FIG. 1 SPRAY NOZZLE

7 PROCEDURE

Place 1.000 g of sample of the cement on a clean, dry 45 micron IS Sieve. Wet the sample thoroughly with a gentle stream of water. Remove the sieve from under the nozzle and adjust the pressure on the spray nozzle to 0.07 ± 0.005 N/mm². Return the sieve to its position under the nozzle and wash for 1 min, moving the sieve with a circular motion in a horizontal plane at the rate of one motion per second in the spray. The bottom of the spray nozzle shall extend below the top of the sieve frame by about 12 mm. Immediately upon removing the sieve from the spray, rinse once with 50 ml of distilled water, taking care not to lose any of the residue, and then blot the lower surface gently upon a damp cloth. Dry the sieve and residue in an oven or over a hot plate (see Note), supporting the sieve in such a manner that air may pass freely beneath it. Cool the sieve, brush the residue from the sieve and weigh.

NOTE — Care should be taken not to heat the sieve hot enough to soften the solder.

8 CALCULATION

Calculate the mass of the residue of the cement left on the standard 45 micron IS Sieve to the nearest 0.1 percent as follows:

$$R_c = R_s \times (100 + C)$$

where

R_c = corrected residue in percent,

R_s = residue of the sample retained on the 45 micron IS Sieve in g, and

C = sieve correction factor which may be either plus or minus.

Example:

Sieve correction factor, $C = + 33.3$ percent

Residue from sample being tested, $R_s = 0.092$ g

$$\text{Corrected residue} = 0.092 \times (100 + 33.3) = 12.3 \text{ percent}$$

ANNEX A**(Foreword)****COMPOSITION OF THE TECHNICAL COMMITTEE****Cement and Concrete Sectional Committee, CED 2**

<i>Chairman</i>	<i>Representing</i>
DR H. C. VISVESVARAYA	In personal capacity (<i>University of Roorkee, Roorkee 247667</i>)
<i>Members</i>	
SHRI H. BHATTACHARYA	Orissa Cement Limited, New Delhi
DR A. K. CHATTERJEE	The Associated Cement Companies Ltd, Bombay
SHRI S. H. SUBRAMANIAN (<i>Alternate</i>)	
CHIEF ENGINEER (DESIGNS)	Central Public Works Department, New Delhi
SUPERINTENDING ENGINEER (S & S)	
(<i>Alternate</i>)	
CHIEF ENGINEER, NAVAGAM DAM	Sardar Sarovar Narmada Nigam Ltd, Gandhinagar
SUPERINTENDING ENGINEER, OCC	
(<i>Alternate</i>)	
CHIEF ENGINEER (RESEARCH-CUM-DIRECTOR)	Irrigation and Power Research Institute, Amritsar
RESEARCH OFFICER (CONCRETE TECHNOLOGY) (<i>Alternate</i>)	
DIRECTOR	A. P. Engineering Research Laboratories, Hyderabad
JOINT DIRECTOR (<i>Alternate</i>)	
DIRECTOR (C & MDD) (N & W)	Central Water Commission, New Delhi
DEPUTY DIRECTOR (C & MDD)	
(NW & S) (<i>Alternate</i>)	
SHRI K. H. GANGWAL	Hyderabad Industries Limited, Hyderabad
SHRI V. PATTABHI (<i>Alternate</i>)	
SHRI V. K. GHANEKAR	Structural Engineering Research Centre (CSIR), Ghaziabad
SHRI S. GOPINATH	The India Cements Limited, Madras
SHRI R. TAAMILAKARAN (<i>Alternate</i>)	
SHRI S. K. GUHA THAKURTA	Gannon Dunkerley & Company Limited, Bombay
SHRI S. P. SHANKARANARAYANAN	
(<i>Alternate</i>)	
DR IRSHAD MASOOD -	Central Building Research Institute (CSIR), Roorkee
DR MD KHALID (<i>Alternate</i>)	
JOINT DIRECTOR, STANDARDS (B & S) (CB-I)	Research, Designs and Standards Organization (Ministry of Railways), Lucknow
JOINT DIRECTOR STANDARDS (B & S) /	
(CB-II) (<i>Alternate</i>)	
SHRI N. G. JOSHI	Indian Hume Pipes Co Limited, Bombay
SHRI P. D. KELKAR (<i>Alternate</i>)	
SHRI D. K. KANUNGO	National Test House, Calcutta
SHRI B. R. MEENA (<i>Alternate</i>)	
SHRI P. KRISHNAMURTHY	Larsen and Toubro Limited, Bombay
SHRI S. CHAKRAVARTHY (<i>Alternate</i>)	
SHRI G. K. MAJUMDAR	Hospital Services Consultancy Corporation (India) Ltd, New Delhi
SHRI S. O. RANGARI (<i>Alternate</i>)	
SHRI P. N. MEHTA	Geological Survey of India, Calcutta
SHRI J. S. SANGANERIA (<i>Alternate</i>)	
MEMBER SECRETARY	Central Board of Irrigation and Power, New Delhi
DIRECTOR (CIVIL) (<i>Alternate</i>)	
SHRI M. K. MUKHERJEE	Roads Wing Department of Surface Transport (Ministry of Transport), New Delhi
SHRI M. K. GHOSH (<i>Alternate</i>)	
DR A. K. MULLICK	National Council for Cement and Building Materials, New Delhi
DR S. C. AHLUWALIA (<i>Alternate</i>)	
SHRI NIRMAL SINGH	Development Commissioner for Cement Industry (Ministry of Industry)
SHRI S. S. MIGLANI (<i>Alternate</i>)	
SHRI R. C. PARATE	Engineer-in-Chief's Branch, Army Headquarters
LT-COL R. K. SINGH (<i>Alternate</i>)	

IS 4031 (Part 15) : 1991

Members

SHRI H. S. PASRICHA
SHRI Y. R. PHULL
SHRI S. S. SEEHRA (*Alternate*)
SHRI Y. R. PHULL
SHRI K. B. THANDEVAN (*Alternate*)
DR M. RAMAIAH
DR A. G. MADHAVA RAO (*Alternate*)
SHRI G. RAMDAS
REPRESENTATIVE
SHRI A. U. RIHSINGHANI
SHRI C. S. SHARMA (*Alternate*)
SHRI J. SEN GUPTA
SHRI A. K. LAL (*Alternate*)
SHRI T. N. SUBBA RAO
SHRI S. A. REDDI (*Alternate*)
SUPT. ENGINEER (DESIGNS)
EXECUTIVE ENGINEER (S.M.R. DIVISION)
(*Alternate*)
SHRI S. B. SURI
SHRI N. CHANDRASEKARAN (*Alternate*)
DR H. C. VISVESVARAYA
SHRI D. C. CHATURVEDI (*Alternate*)
SHRI G. RAMAN,
Director (Civil Engg)

Representing

Hindustan Prefab Ltd, New Delhi
Central Road Research Institute (CSIR), New Delhi
Indian Roads Congress, New Delhi
Structural Engineering Research Centre (CSIR), Madras
Directorate General of Supplies and Disposals, New Delhi
Builders Association of India, Bombay
Cement Corporation of India, New Delhi
National Buildings Organization, New Delhi
Gammon India Limited, Bombay
Public Works Department, Government of Tamil Nadu
Central Soil and Materials Research Station, New Delhi
The Institution of Engineers (India), Calcutta
Director General, BIS (*Ex-officio Member*)

Secretary

SHRI N. C. BANDYOPADHYAY
Joint Director (Civil Engg), BIS

Cement, Pozzolana and Cement Additives Subcommittee, CED 2 : 1

Convener

DR H. C. VISVESVARAYA

In personal capacity (*University of Roorkee, Roorkee 247667*)

Members

SHRI S. K. BANERJEE
SHRI N. G. BASAK
SHRI T. MADNESHWAR (*Alternate*)
SHRI SOMNATH BANERJEE
CHIEF ENGINEER (RESEARCH-CUM-DIRECTOR)
RESEARCH OFFICER (CT) (*Alternate*)
SHRI N. B. DESAI
SHRI J. K. PATEL (*Alternate*)
DIRECTOR
RESEARCH OFFICER (*Alternate*)
DIRECTOR (C & MDD II)
DEPUTY DIRECTOR (C & MDD II)
(*Alternate*)
SHRI R. K. GATTANI
SHRI R. K. VAISHNAVI (*Alternate*)
SHRI P. J. JAGUS
DR A. K. CHATTERJEE (*Alternate*)
JOINT DIRECTOR (MATERIALS)
ASSTT DIRECTOR (PLASTIC) (*Alternate*)
JOINT DIRECTOR STANDARDS (B & S) (CB-1)
JOINT DIRECTOR, STANDARDS (B & S)
(CB-II) (*Alternate*)
SHRI R. L. KAPOOR
SHRI R. K. DATTA (*Alternate*)
SHRI W. N. KARODE
SHRI R. KUNJITHAPATTAM

National Test House, Calcutta
Directorate General of Technical Development, New Delhi
Cement Manufacturers Association, Bombay
Irrigation Department, Government of Punjab
Gujarat Engineering Research Institute, Vadodara
Maharashtra Engineering Research Institute, Nasik
Central Water Commission, New Delhi
Shree Digvijay Cement Co Ltd, Bombay
The Associated Cement Companies Ltd, Bombay
National Buildings Organization, New Delhi
Research, Designs and Standards Organization (Ministry of
Railways), Lucknow
Roads Wing, Department of Surface Transport, Ministry of
Transport, New Delhi
The Hindustan Construction Co Ltd, Bombay
Chettinad Cement Corporation Ltd, Poliyur, Tamil Nadu

Members

SHRI G. K. MAJUMDAR
DR IRSHAD MASOOD
SHRI K. P. MOHIDEEN
DR A. K. MULLICK
DR (SMT) S. LAXMI (*Alternate*)
SHRI K. NARANAPPA
SHRI D. P. KEWALRAMANI (*Alternate*)
SHRI NIRMAL SINGH
SHRI S. S. MIGLANI (*Alternate*)
SHRI Y. R. PHULL
SHRI S. S. SEEHRA (*Alternate*)
SHRI A. V. RAMANA
DR K. C. NARANG (*Alternate*)
COL V. K. RAO
SHRI N. S. GALANDE (*Alternate*)
SHRI S. A. REDDI
SHRI A. U. RIJHSINGHANI
SHRI M. P. SINGH
SUPERINTENDING ENGINEER (D)
SENIOR DEPUTY CHIEF ENGINEER
(GENERAL) (*Alternate*)
SHRI S. B. SURI
SHRI N. CHANDRASEKARAN (*Alternate*)
SHRI L. SWAROOP
SHRI H. BHATTACHARYA (*Alternate*)
SHRI V. M. WAD

Representing

Hospital Services Consultancy Corporation (India) Ltd,
New Delhi
Central Building Research Institute (CSIR), Roorkee
Central Warehousing Corporation, New Delhi
National Council for Cement and Building Materials, New Delhi
Central Electricity Authority, New Delhi
Development Commissioner for Cement Industry (Ministry of
Industry)
Central Road Research Institute (CSIR), New Delhi
Dalmia Cement (Bharat) Ltd, New Delhi
Engineer-in-Chief's Branch, Army Headquarters
Gammon India Ltd, Bombay
Cement Corporation of India Ltd, New Delhi
Federation of Mini Cement Plants, New Delhi
Public Works Department, Govt of Tamil Nadu
Central Soil and Materials Research Station, New Delhi
Orissa Cement Ltd, New Delhi
Bhilai Steel Plant, Bhilai

Bureau of Indian Standards

BIS is a statutory institution established under the *Bureau of Indian Standards Act, 1986* to promote harmonious development of the activities of standardization, marking and quality certification of goods and attending to connected matters in the country.

Copyright

BIS has the copyright of all its publications. No part of these publications may be reproduced in any form without the prior permission in writing of BIS. This does not preclude the free use, in the course of implementing the standard, of necessary details, such as symbols and sizes, type or grade designations. Enquiries relating to copyright be addressed to the Director (Publication), BIS.

Review of Indian Standards

Amendments are issued to standards as the need arises on the basis of comments. Standards are also reviewed periodically; a standard along with amendments is reaffirmed when such review indicates that no changes are needed; if the review indicates that changes are needed, it is taken up for revision. Users of Indian Standards should ascertain that they are in possession of the latest amendments or edition by referring to the latest issue of 'BIS Handbook' and 'Standards Monthly Additions'.

This Indian Standard has been developed from Doc: No. CED 2 (4767)

Amendments Issued Since Publication

Amend No.	Date of Issue	Text Affected

BUREAU OF INDIAN STANDARDS

Headquarters:

Manak Bhavan, 9 Bahadur Shah Zafar Marg, New Delhi 110002
Telephones: 323 01 31, 323 33 75, 323 94 02

Telegrams: Manaksanstha
(Common to all offices)

Regional Offices:

Central : Manak Bhavan, 9 Bahadur Shah Zafar Marg
NEW DELHI 110002

Telephone
323 76 17, 323 38 41

Eastern : 1/14 C.I.T. Scheme VII M, V.I.P. Road, Maniktola
CALCUTTA 700054

{ 337 84 99, 337 85 61
337 86 26, 337 91 20

Northern : SCO 335-336, Sector 34-A, CHANDIGARH 160022

{ 60 38 43
60 20 25

Southern : C.I.T. Campus, IV Cross Road, CHENNAI 600113

{ 235 02 16, 235 04 42
235 15 19, 235 23 15

Western : Manakalaya, E9 MIDC, Marol, Andheri (East)
MUMBAI 400093

{ 832 92 95, 832 78 58
832 78 91, 832 78 92

Branches : AHMADABAD. BANGALORE. BHOPAL. BHUBANESHWAR.
COIMBATORE. FARIDABAD. GHAZIABAD. GUWAHATI.
HYDERABAD. JAIPUR. KANPUR. LUCKNOW. NAGPUR.
PATNA. PUNE. THIRUVANANTHAPURAM.