



TABLE

POCKET MARK	NO. OF FOUNDATION BOLT/POCKET	BOLT SIZE	POCKET SIZE A X B	POCKET DEPTH	POCKET LENGTH	STATIC LOAD/POCKET Kgs.	DYNAMIC LOAD/POCKET Kgs.	NO. OF POCKETS
P1	1	M24	150 SQ.	600 DEEP	600	600	-	6
P2	2	M24	350 x 150	600 DEEP	600	250	-	4
P3	1	M24	150 SQ.	600 DEEP	600	600	-	5
P4	2	M24	350 x 150	600 DEEP	600	600	-	2
P5	1	M20	100 SQ.	350 DEEP	50	-	-	2

NOTES :-

- MIX OF CONC. M-25 FOR ALL R.C.C. WORK.
- Ø INDICATES TOR STEEL BARS DIA IN mm. & FE 500D GRADE STEEL TO BE USED, SATISFYING THE RELEVANT CODES.
- DO NOT SCALE THE DRAWING.
- CLEAR COVER FOR FOOTING-50mm BLOCKS.
- REFER DRG. NO- CB837-00-03-3-007.
- BEARING CAPACITY AND LEVELS SUPPLIED BY CLIENT.

STR DETAIL OF SA FAN FOUNDATION.

DESIGNED FOR:- M/S NAWANSHAHAR POWER (P) LIMITED

DESIGNED BY:-

Dr. Hardeep Singh

ENDORSED BY:-

Dr. Hardeep Singh Rai
Dean Testing & Consultancy

PRELIMINARY DRAWING.